

**PLANNED MAINTENANCE AGREEMENT**


<u>Customer Address</u>	<u>Customer Contact</u>	<u>Quote Information</u>
VERMILION COUNTY HEALTH DEPARTMENT 200 S COLLEGE SUITE A Danville, IL 61832	Contact: Mark Cravens Phone: 217 304-1835 Fax: 217 554-6024 Cust Id: 495199	Quote Date: 17-JUN-13 Quote Expires: 17-JUN-14 Quote Num: 15420 Quoted By: Bob Mizell Quote Term: 1 Year(s)


<u>Site Information</u>					
1	VERMILION COUNTY	200 S COLLEGE SUITE A	DANVILLE	IL	61832

<u>Site Unit Number</u>	<u>Manufacturer</u>	<u>Model</u>	<u>Prod Model</u>	<u>Serial Number</u>	<u>Type</u>
1	D080177074	ONAN	GEN SET	150DSGAC	D080177074 ST

<u>Site Unit Number</u>	<u>Service Event</u>	<u>Qty</u>	<u>Sell Price</u>	<u>Extended Price</u>	
1	D080177074	"D" CHECK (FULL SERVICE)	1	949.51	949.51
			Total Parts:	198.75	
			Parts Discount:		.00-
			Total Labor:	612.00	
			Labor Discount:		.00-
			Total Miscellaneous:	138.76	
		Miscellaneous Details:	CUST MILE	135.00	
			ECO	3.76	

<b>Standard Agreement Amount</b>	<b>\$949.51</b>
<b>Proposal Total</b>	<b>\$949.51</b>

Customer Approval  
 Signature:   
 Date: 6/24/13

CUMMINS CROSSPOINT, LLC  
 Signature:   
 Date: 06/17/2013



Crosspoint

CUMMINS CROSSPOINT, LLC  
 PLANNED MAINTENANCE CHECK SHEET

"A"-Inspection  "D"-Full Service

CUSTOMER: \_\_\_\_\_ SITE: \_\_\_\_\_ W.O.#: \_\_\_\_\_ DATE: \_\_\_\_\_  
 GENERATOR MAKE: \_\_\_\_\_ GENERATOR MODEL: \_\_\_\_\_ GENERATOR SN: \_\_\_\_\_ KWH: \_\_\_\_\_  
 ENGINE MAKE: \_\_\_\_\_ ENGINE MODEL: \_\_\_\_\_ ENGINE SN: \_\_\_\_\_ HOURS: \_\_\_\_\_  
 TRANSFER SWITCH MAKE: \_\_\_\_\_ TRANSFER SWITCH MODEL: \_\_\_\_\_ TRANSFER SWITCH SN: \_\_\_\_\_  
 TECHNICIAN SIGNATURE: \_\_\_\_\_  
 CUSTOMER SIGNATURE: \_\_\_\_\_

**\* Services in Bold and Italics are included during a "D" Check (Full Service) only.**

OK Needs Attention (U, P, A, R, or C)	OK Needs Attention (U, P, A, R, or C)
<b>GAS</b>	<b>FUEL SYSTEM</b>
<input type="checkbox"/> CHECK CONDITION & TENSION OF ALL BELTS.	<input type="checkbox"/> VISUALLY CHECK FUEL LINES & CONNECTIONS.
<input type="checkbox"/> CHECK CARBURETOR ADJUSTMENT.	<input type="checkbox"/> VISUALLY CHECK DAY TANK FUEL LEVEL.
<input type="checkbox"/> CHECK GAS PRESSURE ON LPG/GAS UNITS & CLEAN REGULATOR VENT.	<input type="checkbox"/> VISUALLY CHECK FOR FUEL LEAKS.
<input type="checkbox"/> VISUALLY INSPECT SPARK PLUGS, IGNITION POINTS, CAP, ROTOR, & WIRES.	<input type="checkbox"/> CHECK TRANSFER OR DAY TANK PUMP.
<b>DIESEL</b>	<b>*CHANGE FUEL FILTER(S) &amp; CLEAN FUEL BOWL. (if applicable)</b>
<input type="checkbox"/> CHECK CONDITION & TENSION OF ALL BELTS.	<b>ELECTRICAL</b>
<input type="checkbox"/> CHECK SUPERTURBOCHARGER FOR LEAKS & WEAR.	<input type="checkbox"/> VISUALLY INSPECT AC/DC BRUSHES & COMMUTATOR. (if applicable)
<b>LUBRICATING OIL SYSTEM</b>	<input type="checkbox"/> VISUALLY INSPECT COMMUTATOR. (if applicable)
<input type="checkbox"/> VISUALLY CHECK LUBE OIL CONDITION & LEVEL.	<input type="checkbox"/> VISUALLY INSPECT COLLECTOR RING. (if applicable)
<input type="checkbox"/> VISUALLY CHECK FOR OIL LEAKS.	<input type="checkbox"/> VISUALLY INSPECT ELECTRICAL CONNECTIONS.
<input type="checkbox"/> VISUALLY CHECK HYDRAULIC GOVERNOR OIL LEVEL. (if applicable)	<b>BATTERY</b>
<input type="checkbox"/> *CHANGE LUBE OIL.	<input type="checkbox"/> VISUALLY CHECK CONNECTIONS & CLEAN IF NEEDED.
<input type="checkbox"/> *CHANGE LUBE OIL FILTER(S).	<input type="checkbox"/> VISUALLY CHECK BATTERY CONDITION & SOLUTION LEVEL.
<input type="checkbox"/> *CHANGE HYDRAULIC GOVERNOR OIL. (if applicable)	<input type="checkbox"/> RECORD CRANKING VOLTAGE _____ VDC.
<b>COOLING SYSTEM</b>	<input type="checkbox"/> NOTE OVERALL CONDITION OF BATTERY SYSTEM.
<input type="checkbox"/> VISUALLY CHECK COOLANT CONDITION & LEVEL.	<input type="checkbox"/> CHECK CONDITION OF CHARGER AND RECORD BATTERY CHARGER AMPS AND VOLTS _____
<input type="checkbox"/> RECORD ANTI-FREEZE PROTECTION LEVEL.	<b>OPERATING CHECK</b>
<input type="checkbox"/> RECORD DCA PROTECTION LEVEL.	<input type="checkbox"/> RUN & CHECK FOR PROPER: LUBE OIL PRESSURE, WATER TEMP, VOLTAGE, COOLANT TEMP, OIL TEMP, ALTERNATOR CHARGE RATE, AND FREQUENCY.
<input type="checkbox"/> VISUALLY CHECK FOR COOLANT LEAKS.	<input type="checkbox"/> RUN & CHECK FOR NORMAL OPERATION & LEAKS.
<input type="checkbox"/> VISUALLY CHECK OPERATION OF COOLANT HEATER.	<input type="checkbox"/> CHECK FOR VIBRATION.
<input type="checkbox"/> VISUALLY CHECK CONDITION OF COOLANT HOSES.	<input type="checkbox"/> VISUALLY CHECK OPERATION OF LOUVERS.
<input type="checkbox"/> CHECK CONDITION AND OPERATION OF REMOTE RADIATOR. (if applicable)	<input type="checkbox"/> CHECK FOR PROPER GOVERNOR OPERATION.
<input type="checkbox"/> *CHANGE COOLANT FILTER.	<input type="checkbox"/> RETURN SYSTEM TO AUTO.
<b>EXHAUST SYSTEM</b>	<b>AUTOMATIC TRANSFER SWITCH</b>
<input type="checkbox"/> VISUALLY CHECK EXHAUST SYSTEM CONDITION & FOR LEAKS.	<input type="checkbox"/> CHECK OUTPUT OF GENERATOR AC VOLTAGE.
<b>AIR INDUCTION SYSTEM</b>	<input type="checkbox"/> CHECK CONDITION OF VOLTAGE SENSORS.
<input type="checkbox"/> INSPECT AIR CLEANER & REMOVE DUST. (DRY TYPE FILTERS)	<input type="checkbox"/> CHECK FOR PROPER ADJUSTMENT OF TIMERS. (if applicable)
<input type="checkbox"/> VISUALLY CHECK HOSES, CLAMPS, AND AIR RESTRICTION INDICATOR.	<input type="checkbox"/> CHECK FOR PROPER ADJUSTMENT OF START RELAY.
<input type="checkbox"/> *CHANGE OIL. (WET TYPE FILTER)	<input type="checkbox"/> EXERCISER GLIDER
<input type="checkbox"/> VISUALLY CHECK AIR & VENT TUBE CONNECTIONS.	<input type="checkbox"/> VISUALLY CHECK FOR PROPER OPERATION.
<input type="checkbox"/> *CLEAN AND INSPECT CRANKCASE BREATHER.	

**OPERATING CHECK RECORDS**  
 ENGINE LUBE OIL PRESSURE: \_\_\_\_\_  
 ENGINE COOLANT TEMPERATURE: \_\_\_\_\_  
 LUBE OIL TEMPERATURE: \_\_\_\_\_  
 ALTERNATOR CHARGE RATE: \_\_\_\_\_  
 VOLTAGE: \_\_\_\_\_  
 FREQUENCY: \_\_\_\_\_  
**BUILDING LOAD TEST (IF PERMITTED)**  
 GENERATOR CHECK/RECORD AMPS:  
 A \_\_\_\_\_ B \_\_\_\_\_ C \_\_\_\_\_

**LEGEND**  
 U = URGENT PROBLEM  
 P = POTENTIAL PROBLEM  
 A = ADJUST  
 R = REPAIR  
 C = CHANGE (OR REPLACE)